SIEMENS

Data sheet 3RN2012-1BA30



Thermistor motor protection relay Standard evaluation unit 22.5 mm enclosure screw terminal 2 change-over contacts US = 24 V AC/DC Manual/Auto/Remote reset with ATEX approval 2 LEDs (READY/TRIPPED) galvanic isolation Test/reset button Wire break monitoring Short circuit monitoring non-volatile

SIRIUS
SIRIUS 3RN2 thermistor motor protection
Thermistor motor protection relay
Standard evaluation unit with ATEX approval, open-circuit and short-circuit detection in the sensor circuit, non-volatile
3RN2
thermistor motor protection
Yes
1.2 W
1.2 W
300 V
3
4 kV
IP20
11g / 15 ms
10 55 Hz: 0.35 mm
10 000 000
100 000
5 A
K
28.05.2009
Yes
AC/DC
24 24 V
24 24 V
24 24 V

operating range factor control supply voltage rated value at DC	
- 	0.05
• initial value	0.85
• full-scale value	1.1
operating range factor control supply voltage rated value at AC at 50 Hz	
initial value	0.85
full-scale value	1.1
operating range factor control supply voltage rated value at AC at 60 Hz	
initial value	0.85
full-scale value	1.1
inrush current peak	
● at 24 V	0.5 A
duration of inrush current peak	
• at 24 V	50 ms
Measuring circuit	
buffering time in the event of power failure minimum	40 ms
Precision	
relative metering precision	2 %
Auxiliary circuit	
material of switching contacts	AgSnO2
number of NC contacts for auxiliary contacts	0
number of NO contacts for auxiliary contacts	0
number of CO contacts for auxiliary contacts	2
operational current of auxiliary contacts at DC-13	
• at 24 V	1 A
● at 125 V	0.2 A
● at 250 V	0.1 A
Main circuit	
operating frequency rated value	50 60 Hz
ampacity of the output relay at AC-15 at 250 V at 50/60 Hz	3 A
ampacity of the output relay at DC-13	
● at 24 V	1 A
● at 125 V	0.2 A
continuous current of the DIAZED fuse link of the output relay	6 A
Electromagnetic compatibility	
conducted interference	
due to burst acc. to IEC 61000-4-4	2 kV (power ports) / 1 kV (signal ports)
 due to conductor-earth surge acc. to IEC 61000-4-5 	2 kV (line to ground)
 due to conductor-conductor surge acc. to IEC 61000-4-5 	1 kV (line to line)
electrostatic discharge acc. to IEC 61000-4-2	6 kV contact discharge / 8 kV air discharge
Galvanic isolation	
design of the electrical isolation	galvanic isolation
galvanic isolation	
 between input and output 	Yes
 between the outputs 	Yes
 between the voltage supply and other circuits 	No
Safety related data	
Safety Integrity Level (SIL) acc. to IEC 61508	1
performance level (PL) acc. to EN ISO 13849-1	С
category acc. to EN ISO 13849-1	1
Safe failure fraction (SFF)	74 %
average diagnostic coverage level (DCavg)	18 %
failure rate [FIT]	
 at rate of recognizable hazardous failures (λdd) 	0.00000068 1/h
 at rate of non-recognizable hazardous failures (λdu) 	0.00000031 1/h
PFHD with high demand rate acc. to EN 62061	0.00000038 1/h

PFDavg with low demand rate acc. to IEC 61508 MTBF	0.0041 97 y	
MTTFd	303 y	
hardware fault tolerance acc. to IEC 61508	0	
T1 value for proof test interval or service life acc. to IEC 61508	3 y	
Connections/ Terminals		
product component removable terminal for auxiliary	Yes	
and control circuit		
type of electrical connection	screw-type terminals	
for auxiliary and control circuit	screw-type terminals	
type of connectable conductor cross-sections	4 (0 7 4 0 8) 0 (0 7 0 7 8)	
• solid	1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²)	
finely stranded with core end processing	1x (0.5 4 mm²), 2x (0.5 1.5 mm²)	
at AWG cables solid	1x (20 12), 2x (20 14)	
connectable conductor cross-section		
• solid	0.5 4 mm ²	
finely stranded with core end processing	0.5 4 mm²	
AWG number as coded connectable conductor cross section		
• solid	20 12	
• stranded	20 12	
tightening torque with screw-type terminals	0.6 0.8 N·m	
Installation/ mounting/ dimensions		
mounting position	any	
fastening method	screw and snap-on mounting onto 35 mm standard mounting re	ail
height	100 mm	
width	22.5 mm	
depth	90 mm	
required spacing		
with side-by-side mounting		
— forwards	0 mm	
— backwards	0 mm	
— upwards	0 mm	
— downwards	0 mm	
— at the side	0 mm	
for grounded parts		
— forwards	0 mm	
— backwards	OHIIII	
— Dackwarus	0 mm	
— backwards — upwards		
	0 mm	
— upwards	0 mm 0 mm	
— upwards— at the side	0 mm 0 mm 0 mm	
— upwards— at the side— downwards	0 mm 0 mm 0 mm	
upwardsat the sidedownwardsfor live parts	0 mm 0 mm 0 mm 0 mm	
 upwards at the side downwards for live parts forwards 	0 mm 0 mm 0 mm 0 mm	
 upwards at the side downwards for live parts forwards backwards 	0 mm 0 mm 0 mm 0 mm 0 mm	
 — upwards — at the side — downwards • for live parts — forwards — backwards — upwards 	0 mm	
 — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — downwards 	0 mm	
 upwards at the side downwards for live parts forwards backwards upwards downwards at the side 	0 mm	
 — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — downwards — at the side Ambient conditions	0 mm	
 — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — downwards — at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature 	0 mm	
 upwards at the side downwards for live parts forwards backwards upwards downwards at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature during operation 	0 mm	
 upwards at the side downwards for live parts forwards backwards upwards downwards at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature during operation during storage 	0 mm	
- upwards - at the side - downwards • for live parts - forwards - backwards - upwards - downwards - at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature • during operation • during storage • during transport	0 mm	
- upwards - at the side - downwards • for live parts - forwards - backwards - upwards - downwards - at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature • during operation • during storage • during transport relative humidity during operation	0 mm	
- upwards - at the side - downwards • for live parts - forwards - backwards - upwards - downwards - at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature • during operation • during storage • during transport relative humidity during operation explosion protection category for dust	0 mm	
- upwards - at the side - downwards • for live parts - forwards - backwards - upwards - downwards - at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature • during operation • during storage • during transport relative humidity during operation explosion protection category for dust explosion protection category for gas	0 mm	
- upwards - at the side - downwards • for live parts - forwards - backwards - upwards - downwards - at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature • during operation • during storage • during transport relative humidity during operation explosion protection category for dust	0 mm	





Confirmation







For use in hazardous locations Declaration of Conformity

Test Certificates

Marine / Shipping





Type Test Certificates/Test Report







other

Confirmation

Further information

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RN2012-1BA30

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RN2012-1BA30

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3RN2012-1BA30

 $Image\ database\ (product\ images,\ 2D\ dimension\ drawings,\ 3D\ models,\ device\ circuit\ diagrams,\ EPLAN\ macros,\ ...)$

http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RN2012-1BA30&lang=en

Characteristic: Derating

https://support.industry.siemens.com/cs/ww/en/ps/3RN2012-1BA30/manual

last modified: 5/1/2021 🖸