## **SIEMENS**

Data sheet 3RN2013-1BW30



Thermistor motor protection relay Standard evaluation unit 22.5 mm enclosure screw terminal 2 change-over contacts US = 24 V-240 V AC/DC Manual/Auto/Remote reset with ATEX approval 2 LEDs (READY/TRIPPED) Safe galvanic isolation Test/reset button Wire break monitoring Short circuit monitoring non-volatile

product brand name	SIRIUS
product category	SIRIUS 3RN2 thermistor motor protection
product designation	Thermistor motor protection relay
design of the product	Standard evaluation unit with ATEX approval, open-circuit and short-circuit detection in the sensor circuit, safe disconnection, non-volatile
product type designation	3RN2
General technical data	
product function	thermistor motor protection
display version LED	Yes
power loss [W] for rated value of the current	
<ul> <li>at AC in hot operating state</li> </ul>	1.7 W
at DC in hot operating state	1.7 W
insulation voltage for overvoltage category III according to IEC 60664 with degree of pollution 3 rated value	300 V
degree of pollution	3
surge voltage resistance rated value	6 kV
maximum permissible voltage for safe isolation	
<ul> <li>between auxiliary and auxiliary circuit</li> </ul>	300 V
<ul> <li>between control and auxiliary circuit</li> </ul>	300 V
protection class IP	IP20
shock resistance acc. to IEC 60068-2-27	11g / 15 ms
vibration resistance acc. to IEC 60068-2-6	10 55 Hz: 0.35 mm
mechanical service life (switching cycles) typical	10 000 000
electrical endurance (switching cycles) at AC-15 at 230 V typical	100 000
thermal current of the switching element with contacts maximum	5 A
reference code acc. to IEC 81346-2	K
Substance Prohibitance (Date)	28.05.2009
Product Function	
product function	
<ul><li>error memory</li></ul>	Yes
<ul> <li>dynamic open-circuit detection</li> </ul>	Yes
<ul> <li>external reset</li> </ul>	Yes
• auto-RESET	Yes
manual RESET	Yes
Control circuit/ Control	
type of voltage of the control supply voltage	AC/DC
control supply voltage at AC	
<ul> <li>at 50 Hz rated value</li> </ul>	24 240 V

	04 04014
at 60 Hz rated value	24 240 V
control supply voltage at DC	24 240 V
• rated value	24 240 V
operating range factor control supply voltage rated value at DC	
• initial value	0.85
• full-scale value	1.1
operating range factor control supply voltage rated value at AC at 50 Hz	
initial value	0.85
full-scale value	1.1
operating range factor control supply voltage rated value at AC at 60 Hz	
initial value	0.85
full-scale value	1.1
inrush current peak	
• at 24 V	0.7 A
• at 240 V	12 A
duration of inrush current peak	
• at 24 V	0.25 ms
• at 240 V	0.2 ms
Measuring circuit	
buffering time in the event of power failure minimum	40 ms
Precision	
relative metering precision	2 %
Auxiliary circuit	
material of switching contacts	AgSnO2
number of NC contacts for auxiliary contacts	0
number of NO contacts for auxiliary contacts	0
number of CO contacts for auxiliary contacts	2
operational current of auxiliary contacts at DC-13	
● at 24 V	1 A
● at 125 V	0.2 A
● at 250 V	0.1 A
Main circuit	
operating frequency rated value	50 60 Hz
ampacity of the output relay at AC-15 at 250 V at 50/60 Hz	3 A
ampacity of the output relay at DC-13	
• at 24 V	1 A
● at 125 V	0.2 A
continuous current of the DIAZED fuse link of the output relay	6 A
Electromagnetic compatibility	
conducted interference	
• due to burst acc. to IEC 61000-4-4	2 kV (power ports) / 1 kV (signal ports)
• due to conductor-earth surge acc. to IEC 61000-4-5	2 kV (line to ground)
<ul> <li>due to conductor-conductor surge acc. to IEC 61000-4-5</li> </ul>	1 kV (line to line)
electrostatic discharge acc. to IEC 61000-4-2	6 kV contact discharge / 8 kV air discharge
Galvanic isolation	
design of the electrical isolation	Protective separation
galvanic isolation	
between input and output	Yes
<ul><li>between the outputs</li></ul>	Yes
<ul> <li>between the voltage supply and other circuits</li> </ul>	Yes
Safety related data	
Safety Integrity Level (SIL) acc. to IEC 61508	·
., ., ., ., .,,,	1
performance level (PL) acc. to EN ISO 13849-1	1 C
performance level (PL) acc. to EN ISO 13849-1 category acc. to EN ISO 13849-1	
performance level (PL) acc. to EN ISO 13849-1 category acc. to EN ISO 13849-1 Safe failure fraction (SFF)	С

average diagnostic coverage level (DCavg)	18 %
failure rate [FIT]	
<ul> <li>at rate of recognizable hazardous failures (λdd)</li> </ul>	0.00000068 1/h
at rate of non-recognizable hazardous failures (λdu)	0.00000031 1/h
PFHD with high demand rate acc. to EN 62061	0.00000038 1/h
PFDavg with low demand rate acc. to IEC 61508	0.0041
MTBF	97 y
MTTFd	303 y
hardware fault tolerance acc. to IEC 61508	0
T1 value for proof test interval or service life acc. to IEC 61508	3 y
Connections/ Terminals	
product component removable terminal for auxiliary and control circuit	Yes
type of electrical connection	screw-type terminals
<ul> <li>for auxiliary and control circuit</li> </ul>	screw-type terminals
type of connectable conductor cross-sections	
• solid	1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²)
finely stranded with core end processing	1x (0.5 4 mm²), 2x (0.5 1.5 mm²)
at AWG cables solid	1x (20 12), 2x (20 14)
connectable conductor cross-section	
• solid	0.5 4 mm²
finely stranded with core end processing	0.5 4 mm²
AWG number as coded connectable conductor cross section	
• solid	20 12
stranded	20 12
tightening torque with screw-type terminals	0.6 0.8 N·m
Installation/ mounting/ dimensions	
mounting position	any
	•
fastening method	screw and snap-on mounting onto 35 mm standard mounting rail
	screw and snap-on mounting onto 35 mm standard mounting rail
fastening method height	screw and snap-on mounting onto 35 mm standard mounting rail
fastening method height width	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm
fastening method height width depth required spacing	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm
fastening method height width depth	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm
fastening method height width depth required spacing • with side-by-side mounting	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing • with side-by-side mounting — forwards — backwards — upwards — downwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — backwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — upwards — at upwards — at upwards — at upwards — upwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — backwards — upwards — at the side	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — backwards — upwards — at the side — downwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 m
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — backwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — backwards — upwards	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — backwards — upwards — backwards — backwards — backwards — upwards — downwards	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — backwards — upwards — downwards — backwards — upwards — downwards — at the side	screw and snap-on mounting onto 35 mm standard mounting rail 100 mm 22.5 mm 90 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — forwards — backwards — upwards — backwards — upwards — the side — downwards • for live parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — backwards — upwards — backwards — upwards — backwards — upwards — at the side  Ambient conditions	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — at the side — downwards — at the side Ambient conditions installation altitude at height above sea level maximum	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm
fastening method height width depth required spacing	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 m
fastening method height width depth required spacing	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 m
fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — forwards — backwards — upwards — at the side • for live parts — for live parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — at the side  Ambient conditions installation altitude at height above sea level maximum  ambient temperature • during operation • during storage	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 m
fastening method height width depth required spacing	screw and snap-on mounting onto 35 mm standard mounting rail  100 mm  22.5 mm  90 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 m

 explosion protection category for dust
 [Ex t] [Ex p]

 explosion protection category for gas
 [Ex e] [Ex d] [Ex px]

Certificates/ approvals

**General Product Approval** 

**EMC** 













For use in hazardous locations Declaration of Conformity

**Test Certificates** 

Marine / Shipping





Type Test Certificates/Test Report







other

Confirmation

## **Further information**

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RN2013-1BW30

Cax online generator

 $\underline{\text{http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3RN2013-1BW30}$ 

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)


https://support.industry.siemens.com/cs/ww/en/ps/3RN2013-1BW30


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3RN2013-1BW30&lang=en

**Characteristic: Derating** 

https://support.industry.siemens.com/cs/ww/en/ps/3RN2013-1BW30/manual







last modified: 5/1/2021 🖸